



NOTE: UNSTABLE SOIL MAY REQUIRE DEEPER FOUNDATION, AS DETERMINED BY ENGINEER.

NOTES:

1. REINF A615 GRADE 60 EXCEPT #3 GRADE 40.
2. TOP OF FOUNDATION SHALL BE FINISHED WITH A SMOOTH SURFACE WITH A 1/2" ROUND EDGE.
3. POLE FOUNDATION SHALL CURE FOR 72 HOURS BEFORE INSTALLING LIGHT POLES.
4. ALL FINISHED POLE FOUNDATIONS SHALL BE AT SIDEWALK GRADE OR TOP OF CURB WHEN IN MEDIAN.
5. ANCHOR BOLTS SHALL BE FULLY GALVANIZED PER ASTM A-135.
6. CONCRETE PLACEMENT SHALL FOLLOW MAG SPECIFICATIONS.
7. DO NOT FREEFALL CONCRETE IN EXCESS OF 5'.
8. A VIBRATOR SHALL BE USED TO DISTRIBUTE CONCRETE & REDUCE AIR VOIDS.
9. MAXIMUM SLUMP SHALL NOT EXCEED 5".
10. CAP SHALL BE POURED SEPARATELY WITH MIN 2500 PSI CONCRETE, MAG STD 725.
11. FOR FUSING & GROUNDING SEE DETAILS FG1 & FG2.
12. *DEPTH OF FOUNDATION SHALL BE VERIFIED BY INSPECTOR PRIOR TO POURING.



STANDARD
DETAIL

CONCRETE FOUNDATION DETAIL

APPROVED

[Signature]
TOWN ENGINEER

12-11-13
DATE

DETAIL NO.
GIL-932