

Fire Inspection Scheduling

No Appointment Required

Access Road – representative required on site, no appointment required, get contact information for representative

Fire Line Test – system must be under test for 2 hours prior to the inspection, Gauge must be able to be bled down without the use of tools

Fire Sprinkler Rough – 50# or 200# test, system must be under test for 2 hours prior to walk down. Gauge must be able to be bled down without the use of tools

Above Ceiling – contractor not required

Fire Alarm Rough – contractor not required

Appointment Required

Fire Line Test and Flush – 2 hour test required, representative required on site, NFPA form required

Fire Line Flush Only - representative required on site, NFPA form required

Fire Sprinkler Final – representative required on site, NFPA form required

Fire Alarm Final – sub-contractor required on site, NFPA form required

Final – representative required on site

Fire Pump – sub-contractor required on site

Hood Test – sub-contractor required on site

Medical Gas Installation – sub-contractor required on site

Spray Booth Inspection – sub-contractor required on site

Courtesy Inspection – representative required on site

NOTE: Approved plans are required on site for all of the above inspections except:

Access Road
Courtesy Inspection

Fire Line Flush Only